PORTABLE APPLIANCE TEST CERTIFICATE

Page 1 of 1

CERT NO. CRE342

FLUKE

Acknowledgement; this certificate is based on the model in appendix 6 of BS 7671: 2001

CLIENT: Thurlaston Village Hall

CONTACT NAME: Selina Larque

DATE OF TEST: 27/11/18

DATE OF INSPECTION: 27/11/18

SITE ADDRESS: 128 Church Lane, Thurlaston CV23 9JY

NEXT TEST DATE: 27/11/19

NEXT INSPECTION DATE: 27/11/19

TECHNICIAN: Craig Randle

EQUIPMENT USED: Seaward PAT 500H

SERIAL NUMBER: X020165

ROOM NO. (location)	APPLIANCE ID NO.	DESCRIPTION	MANUFACTURER	SERIAL NO.	CLASS (I, II, III, IT)	FUSE RATING (Amps)	VISUAL Pass/Fail	TEST TYPE (20A/25A/75A/100mA)	EARTH BOND Ω	EARTH BOND PASS/FAIL	INSULATION MΩ	INSULATION PASS/FAIL	COMMENTS/OTHER TESTS (01 - Replace incorrect fuse) (02 - Refit plug) (03 - Replace plug)	OK TO USE
Kitchen	1	Microwave	Russell Hobbs	032607070000563	1	13	Pass	20A	0.07	Pass	>999	Pass	Leakage 0.06mΩ	✓
kitchen	2	Kettle	Wilko	130415	1	13	Pass	20A	0.03	Pass	>999	Pass	Leakage 0.03mΩ	✓
kitchen	3	Bosch kettle	Bosch	FD9412	1	13	Pass	20A	0.04	Pass	>999	Pass	Leakage 0.04mΩ	✓
kitchen	4	Kettle	Russell Hobbs	20070	1	13	Pass	20A	0.02	Pass	>999	Pass	Leakage 0.07mΩ	✓
kitchen	5	Kettle	Bosch	FD9412	1	13	Pass	20A	0.06	Pass	>999	Pass	Leakage 0.03mΩ	✓
kitchen	6	Freestand Water Boiler	Bartlett	N/A	1	13	Pass	20A	0.04	Pass	>999	Pass	Leakage 0.04mΩ	✓
kitchen	7	Fridge	Logik	1723006314	1	13	Pass	20A	0.09	Pass	>999	Pass	Leakage 0.02mΩ	✓

© Signal International Ltd.